

[Opravný součinitel kt na odlišný teplotní rozdíl Δt (K)

KORAFLEX FV 11/34 InPool

Δt (K)	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33
kt	0,325	0,345	0,365	0,385	0,405	0,426	0,446	0,467	0,487	0,508	0,528	0,549	0,570	0,591	0,612	0,633
Δt (K)	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49
kt	0,654	0,675	0,697	0,718	0,739	0,761	0,782	0,804	0,825	0,847	0,869	0,891	0,912	0,934	0,956	0,978
Δt (K)	50	51	52	53	54	55	56	57	58	59	60					
kt	1,000	1,022	1,044	1,066	1,088	1,111	1,133	1,155	1,177	1,200	1,222					

- teplotní exponent $m = 1,1$